



Government Of West Bengal
Office Of The Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services
6, Diamond Harbour Road, Silpara, Kol-700008

Memo no.:FSR/0125186201202510

Date: 10-09-2021

From:
Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services

To: J.C.MEMORIAL INTERNATIONAL SCHOOL.
VILL.-NARAHARIPUR,P.O.-SAGAR KRISHNANAGAR,P.S.SAGAR,DIST.-24-PGS.(S),WEST BENGAL PIN-743373.

Sub: Fire safety Certificate(Part) for a Single storied under group Educational Occupancy at the premises No.-
VILL.-NARAHARIPUR,P.O.-SAGAR KRISHNANAGAR,P.S.SAGAR,DIST.-24-PGS.(S),WEST BENGAL PIN-743373.

This is in reference to your application no. 0125189211200092 dated 03-08-2021 regarding the Fire safety Certificate(Part) for a Single storied under group Educational Occupancy at the premises No.-VILL.-NARAHARIPUR,P.O.-SAGAR KRISHNANAGAR,P.S.SAGAR,DIST.-24-PGS.(S),WEST BENGAL PIN-743373.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. All the fire prevention and fire safety measures shall be maintained in good repair and efficient condition at all times in accordance with the provision of Section 11 C of West Bengal Fire service Act 1950 with up to date amendment.
2. Driveway must be free from any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the driveway.
3. The interior finish decoration of the building shall be with low flame spread material confirming I.S. specification.
4. To eliminate risk of Fire hazards, good housekeeping both for inside and outside of the building shall be strictly maintained.
5. Existing electrical wiring of the whole building shall have to be carefully checked for wear and tear in them, particularly lines above false ceiling.
6. The notice of Fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.
7. The employees and security staff shall be conversant with installed Firefighting equipments of the building and to operate in the event of Fire and testing.
8. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. Electrical switch gear room shall be protected with automatic CO2 or D.C.P Fire extinguisher confirming I.S.

specification.

10. First aid firefighting system shall be provided as per I.S. specification.

11. Arrangement shall have to be made for regular checking, testing and maintenance of all the Firefighting installation in the building to keep them in perfectly good working condition at all the times.

12. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. Conduits pipes continuously bonded with earth.

13. Periodical flashing of water from the fire water pipe line shall be made to maintain efficient working performance of above mentioned system.

14. This F.S.C. is valid for 03(three) years and have to be renewed after every three years from the date of issue of this certificate.

Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services

Memo No.:FSR/01251862/202510